**Drawing Notes:** All substrates should be primed or prepared in accordance with the project specification. Structural substrates shown in this drawing are for illustrative purposes only. All reinforced bitumen membrane side overlaps should be a minimum of 80mm and head laps a minimum of 100mm. Rainwater outlets should be supplied and installed with a suitable outlet guard as determined by the DANOSA flow rate DANOSA rainwater outlets are supplied with a 400mm spigot. Where a full bond to the substrate is required, or where ESTERDAN 30 P ELAST SEMIADHESVIO is used as the underlay, **DANOSA Capsheet** GLASDAN 800 PERFORADO does not form part of the system. (as specification) DANOSA recommends a bead of DANOSEAL sealant (or similar **DANOSA Underlay** method) to create an air-seal around the penetration. This recommendation should be followed in conjunction with any (as specification) internal air-sealing strategy. **GLASDAN 800 PERFORADO** (see Note A) Air Seal (see Note B) Insulation (as specification) Air and Vapour Control Layer (as specification) danosa

Building together **Drawing Title: Drawing Number: Revision:** DUK-B-(G)-300W 01 Rainwater Outlet

**DANOSA UK Limited** 

Tel: 0845 074 0553 | www.danosa.co.uk | uktechnical@danosa.com

**Date Drawn:** 

February 2019

Author:

Reinforced Bitumen Membranes - Warm Roof