

Drawing Notes:

All substrates should be primed or prepared in accordance with the project specification. Structural substrates shown in this drawing are for illustrative purposes only.

All reinforced bitumen membrane side overlaps should be a minimum of 80mm and head laps a minimum of 100mm.

Parapet outlets require a head of water in order to function effectively, so are best located within a gutter or localised sump. The concrete substrate is shown with a sump for illustrative purposes only.

Parapet outlets should be supplied and installed with a suitable outlet guard as determined by the DANOSA flow rate calculation.

DANOSA parapet outlets are supplied with a 600mm spigot.

Note A:

Where a full bond to the substrate is required, or where ESTERDAN 30 P ELAST SEMIADHESVIO is used as the underlay, GLASDAN 800 PERFORADO does not form part of the system.

Important Note: External finishes fall outside of DANOSA specification.



Tel: 0845 074 0553 | www.danosa.co.uk | uktechnical@danosa.com