

Drawing Number: DUK-B-(G)-350C	02	Drawing Title: Integrated Fixing Point (IFP) Reinforced Bitumen Membranes - Cold Roof
Date Drawn: February 2019	Author: SL	

Drawing Notes:

All substrates should be primed or prepared in accordance with the project specification. Structural substrates shown in this drawing are for illustrative purposes only.

All reinforced bitumen membrane side overlaps should be a minimum of 80mm and head laps a minimum of 100mm.

Note A: Where a full bond to the substrate is required, or where ESTERDAN 30 P ELAST SEMIADHESVIO is used as the underlay, GLASDAN 800 PERFORADO does not form part of the system.



Tel: 0845 074 0553 | www.danosa.co.uk | uktechnical@danosa.com