

Drawing Number: DUK-S-(A)-320C	Revision: 00	Drawing Title: Abutment with Lead Counterflashing Adhered DANOPOL® Single Ply Membranes - Cold Roof
Date Drawn: March 2017	Author: SL	

Drawing Notes:

Structural substrates shown in this drawing are for illustrative purposes only.

All DANOPOL membrane hot-air welds should be between 30-40mm. Overlaps should provide sufficient cover to accommodate this requirement.

Note A: Edge restraint bar should be mechanically fastened at 200mm centres.

Note B: Mechanical termination of waterproofing using DANOSA pressure plates, mechanically fastened at 200mm centres.

Note C:

Sealants are considered maintenance items and should be checked and replaced regularly as part of annual roof maintenance procedures.

Note D:

The cavity tray / DPM must discharge over the top of any lead counterflashing,

Note E:

Minimum upstand height is measured from the finished surface of the roof finishes to the first mechanical penetration of the waterproofing or otherwise vulnerable junction. When specifying any finishes, such as paving slabs, stone ballast or a living roof, the measurement is made from the top surface of the finishes, not from the waterproofing level.



DANOSA UK Limited Tel: 0845 074 0553 | www.danosa.co.uk | uktechnical@danosa.com