
Disclaimer: Drawings produced by DANOSA UK should be considered non-scalable at illustrative purposes only, Issued design principals form instructions for the installati DANOSA UK materials only and should be considered as part of a noverall design at than in isolation. Product Technical Datasheets' are available for all DANOSA UK proad should be consulted in conjunction with all issued DANOSA UK installation instructions are subject to copyright and should not be reproduced without permission.



	Drawing Number:	Revision:
	DUK-S-(A)-325C	02
	Date Drawn:	Author:
	February 2019	SL

Drawing Title:

DANOPOL Membrane

(as specification)

Junction with Vertical Cladding
Adhered DANOPOL® Single Ply Membranes - Warm Roof

Drawing Notes:

Structural substrates shown in this drawing are for illustrative purposes only.

All DANOPOL membrane hot-air welds should be between 30-40mm. Overlaps should provide sufficient cover to accommodate this requirement.

Note A:

Edge restraint bar should be mechanically fastened at 200mm centres.

Note B:

Minimum upstand height is measured from the finished surface of the roof finishes to the first mechanical penetration of the waterproofing or otherwise vulnerable junction. When specifying any finishes, such as paving slabs, stone ballast or a living roof, the measurement is made from the top surface of the finishes, not from the waterproofing level.

Note C:

Mechanical restraint, provided by the cladding rail in this illustration, is required at the top edge of the waterproofing.

Note D:

When utilised, any breather membrane behind the cladding system should discharge over the waterproofing system upstand.

