



Drawing Title: **Drawing Number: Revision:** DUK-S-(A)-325W 02 Junction with Vertical Cladding Author: Date Drawn: Adhered DANOPOL<sup>®</sup> Single Ply Membranes - Warm Roof SL February 2019

## **Drawing Notes:**

Structural substrates shown in this drawing are for illustrative purposes only.

All DANOPOL membrane hot-air welds should be between 30-40mm. Overlaps should provide sufficient cover to accommodate this requirement.

Note A:

Edge restraint bar should be mechanically fastened at 200mm centres.

Note B:

Mechanical termination of waterproofing using DANOSA pressure plates, mechanically fastened at 200mm centres.

Note C:

Minimum upstand height is measured from the finished surface of the roof finishes to the first mechanical penetration of the waterproofing or otherwise vulnerable junction. When specifying any finishes, such as paving slabs, stone ballast or a living roof, the measurement is made from the top surface of the finishes, not from the waterproofing level.

Note D:

When utilised, any breather membrane behind the cladding system should discharge over the waterproofing system upstand.



Tel: 0845 074 0553 | www.danosa.co.uk | uktechnical@danosa.com