



Drawing Number: DUK-B-(G)-310W		Drawing Title:
. ,	02	Junction with Tiled / Slate Roof
Date Drawn:	Author:	
February 2019	SL	Reinforced Bitumen Membranes - Warm Roof

## **Drawing Notes:**

All substrates should be primed or prepared in accordance with the project specification. Structural substrates shown in this drawing are for illustrative purposes only.

All reinforced bitumen membrane side overlaps should be a minimum of 80mm and head laps a minimum of 100mm.

Note A: Where a full bond to the substrate is required, or where ESTERDAN 30 P ELAST SEMIADHESVIO is used as the underlay,