Cavity Tray / DPM (see Note E) DANOPRIME+ and DANOSEAL Sealant (see Note C) **DANOPOL Colaminated Termination Metal** (see Note B) Minimum 150mm **Upstand Height** (see Note D) Hot-Air Weld **DANOPOL Membrane Edge Restraint Bar** (as specification) (see Note A) **DANOFELT PP 200** 

# **Drawing Notes:**

Structural substrates shown in this drawing are for illustrative purposes only.

All DANOPOL membrane hot-air welds should be between 30-40mm. Overlaps should provide sufficient cover to accommodate this requirement.

#### Note A:

Edge restraint bar should be mechanically fastened at 200mm centres.

## Note B:

DANOPOL colaminated per-formed metal termination to be mechanically fastened at 200mm centres. Various profiles can be fabricated to suit. Profile shown for illustrative purposes only.

## Note C:

Sealants are considered maintenance items and should be checked and replaced regularly as part of annual roof maintenance procedures.

#### Note D:

Minimum upstand height is measured from the finished surface of the roof finishes to the first mechanical penetration of the waterproofing or otherwise vulnerable junction. When specifying any finishes, such as paving slabs, stone ballast or a living roof, the measurement is made from the top surface of the finishes, not from the waterproofing level.

## Note E

The cavity tray /  $\ensuremath{\mathsf{DPM}}$  must discharge over the top of any lead counterflashing,

Drawing Number:	Revision:
DUK-S-(M)-324C	00
Date Drawn:	Author:
March 2017	SL

Drawing Title:

Abutment with Termination Metal

Mechanically Fastened DANOPOL® Single Ply Membranes - Cold Roof

